



**MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE
16 RAJ PUR ROAD, DELHI - 110054**

DHO/CLZ/2025/.....1128

Dated: 29/8/25

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Public Health department/CLZ, inspected the M/S Joseph & Mary Public School situated at Nathupura Road, Burari, Delhi - 110084 on 29.08.2025 and found that the school is running under sanitary & hygienic conditions from health point of view.

School has safe drinking water facilities for the students and members of staff of the institution and his maintaining the hygiene & sanitation condition in the school building & the campus.

The above Certificate is valid for one year from date of issue.

Principal,
M/S Joseph & Mary Public School
at Nathupura Road, Burari,
Delhi -110084

Signature
Dy. Health Officer
Civil Lines Zone

Deputy Health Officer
Civil Lines Zone
Municipal Corporation of D
16, Rajpur Road, Delhi-1100





DELHI ANALYTICAL RESEARCH LABORATORY

Plot No. 2, (A-2) Timber Block, Jhilmil Industrial Area, Delhi-110095

E-mail : darltesting@gmail.com, www.darltesting.in

Ph.: 011-43545890, 09717324010, 9971520106, 8595224665.

(A GOVERNMENT APPROVED & ISO 9001 : 2015, ISO 45001:2018 Certified Testing Laboratory)



TEST REPORT

Format No. DARL/QF/50

Report Issue to: Joseph & Mary Public School Nathupura Road, Burari Delhi-110084, DELHI		ULR No.:	TC51632600008488F		
		Report No.	820260804WT001		
		Sample Receipt Date	04/05/2028		
		Test Started On	04/05/2028		
		Date of Completion	11/08/2028		
		Issue Date	11/05/2028		
Customer Provided Details					
Name of Sample	Drinking water (School)				
Brand Name	N.S.	Date of Sampling	N.S.		
Sample Quantity	2 Ltr.	Batch/Lot No.	N.S.		
Sample Submitted by	By Party	Manufacturing Date	Not Specified		
Sampling Method	N.S.	Expiry Date	Not Specified		
Sample Description	Drinking water (School)				

TEST RESULTS

Group Name : Water

Discipline : Chemical and Biological

S.No.	Test Parameters	Units	Results	Desirable Limit	Permissible Limit	Test Method
Chemical Parameters						
1	Colour	In Hazen unit	Less than 1	5	May be extended up to 15	IS: 3025 (P-4): 2021 Clause No.-4
2	Odour	--	Agreeable	Agreeable	--	IS: 3025 (P-5):2018 Clause No- 4
3	Turbidity	NTU	Less than 1	1	May be extended up to 5	IS: 3025 (P-10) : 2023 Clause No-7.2
4	pH value	--	6.58	6.5 to 8.5	No Relaxation	IS: 3025 (P-11): 2022 Clause No-9
5	Total dissolved solid	mg/l	52.0	500	2000	IS: 3025 (P-16): 2023 Clause No-7
6	Chloride(as Cl)	mg/l	18.1	250	May be extended up to 1000	IS: 3025 (P-32):1988 Clause No-2
7	Total Hardness (as CaCO3)	mg/l	8.0	200	(May be extended up to 600)	IS:3025(P-21): 2009 Clause No-5



Note: 1. The results are related to the test items only. 2. Sample will be destroyed after one month from the date of issue of test report. 3. This report is not be reproduced wholly or in part and cannot as an evidence in the court of law and should not be used in any advertisement media without written consent. 4. Laboratory is not responsible for customer provided details. 5. When report is without NABL Symbol & URL, It implies that these products & tests are not covered under NABL accredited scope.



DELHI ANALYTICAL RESEARCH LABORATORY

Plot No. 2, (A-2) Timber Block, Jhilmil Industrial Area, Delhi-110095

E-mail : darltesting@gmail.com, www.darltesting.in

Ph.: 011-43545890, 09717324010, 9971520106, 8595224665.

(A GOVERNMENT APPROVED & ISO 9001 : 2015, ISO 45001:2018 Certified Testing Laboratory)



TC-5163



Best for Accreditation & Scope

TEST REPORT

Format No. DARL/QF/50

Report Issue to: Joseph & Mary Public School Nathupura Road, Burari Delhi-110084. DELHI	ULR No.:	TC51632600008486F
	Report No.	820260504WT001
	Sample Receipt Date	04/05/2026
	Test Started On	04/05/2026
	Date of Completion	11/05/2026
	Issue Date	11/05/2026

TEST RESULTS

Group Name : Water

Discipline : Chemical and Biological

S.No.	Test Parameters	Units	Results	Desirable Limit	Permissible Limit	Test Method
8	Iron(As Fe)	mg/l	BLQ(0.1)	1.0	No Relaxation	IS:3025(P-53) : 2024 Clause No- 6.5.4
9	Total Alkalinity (as CaCO ₃)	mg/l	10.1	200	(May be extended up to 600)	IS:3025(P-23) : 2023 Clause No-10
10	Calcium(as Ca)	mg/l	0.8	75	May be extended up to 200	IS:3025(P-40) : 1991 Clause No-5
11	Magnesium (As Mg)	mg/l	1.5	30	May be extended up to 100	IS 3025 (P 46):2023 Clause no. 5
Microbiological Parameters						
12	# E. coli	/100ml	present	Absent	-	IS:15185:2016 Clause No-8
13	# Coliform	/100ml	present	Absent	-	IS:15185:2016 Clause No-8

Note:- 1. BLQ: - Below Limit of Quantification. 2. Figure in bracket Indicate Limit of Quantification.

Remarks : The above tested sample does not complies as per IS: 10500:2012 AMD.No.4:2022 With respect to above test and marked by #.

End of Report



Swati
Review by

Ritu Choudhary
Ritu Choudhary
Authorized Signatory (Biological)

Vikash Sharma
Authorized Signatory (Chemical)
M...
(Chemical & Instrument)

Page No. 2/2

Note: 1. The results are related to the test items only. 2. Sample will be destroyed after one month from the date of issue of test report. 3. This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertisement media without written consent. 4. Laboratory is not responsible for customer provided details. 5. When report is without NABL Symbol & URL, it implies that these products & tests are not covered under NABL accredited scope.



DELHI ANALYTICAL RESEARCH LABORATORY

Plot No. 2, (A-2) Timber Block, Jhilmil Industrial Area, Delhi-110095

E-mail : darltesting@gmail.com, www.darltesting.in

Ph.: 011-43545890, 09717324010, 9971520106, 8595224665.

(A GOVERNMENT APPROVED & ISO 9001:2015, ISO 45001:2018 Certified Testing Laboratory)

TEST REPORT

Format No. DARL/QF/50

Report Issue to:

Joseph & Mary Public School
Nathupura Road, Burari Delhi-110084. DELHI

Report No.	820260504WT001/A
Sample Receipt Date	04/05/2026
Test Started On	04/05/2026
Date of Completion	11/05/2026
Issue Date	11/05/2026

Customer Provided Details

Name of Sample	Drinking water (School)		
Brand Name	N.S.	Date of Sampling	N.S.
Sample Quantity	2 Ltr.	Batch/Lot No.	N.S.
Sample Submitted by	By Party	Manufacturing Date	Not Specified
Sampling Method	N.S.	Expiry Date	Not Specified
Sample Description	Drinking water (School)		

TEST RESULTS

Group Name : Water

Discipline : Chemical and Biological

S.No.	Test Parameters	Units	Results	Desirable Limit	Permissible Limit	Test Method
1	Flouride (as F)	mg/l	BLQ(0.2)	1.0	May be extended up to 1.5	IS 3025 (P 60):2023 Clause no. 7

Note:- 1. BLQ: - Below Limit of Quantification. 2. Figure in bracket Indicate Limit of Quantification.

Remarks : The above tested sample does not complies as per IS: 10500:2012 AMD.No.4:2022 With respect to above test and marked by #.

End of Report



Swati
Review by

Ritu Choudhary
Ritu Choudhary
Authorized Signatory (Biological)

Vikash Sharma
Authorized Signatory
Vikash Sharma
Authorized Signatory (Chemical)
(Chemical & Instrumentation)

Page No. 1/1

Note: 1. The results are related to the test items only. 2. Sample will be destroyed after one month from the date of issue of test report. 3. This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertisement media without written consent. 4. Laboratory is not responsible for customer provided details. 5. When report is without NABL Symbol & URL, it implies that these products & tests are not covered under NABL accredited scope.

