

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2020 / WZ / SCHOOL / 418

Dated: 12 / 10 / 2020

FIRE SAFETY CERTIFICATE

Certified that the Joseph & Mary Public School located at Nathu Pura, Road, Burari, Delhi-110084 comprised of Basement + Ground +02 upper floor owned/ occupied by the Joseph & Mary Public School was granted FSC by this department vide letter F6/DFS/MS/2017/WZ/1402 dated 22.09.2017. The premises was re-inspected by the officer concerned of this department on 28.09.2020 in presence of Sh. Manoj Kr. Shrivastava and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from 12/10/2020 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 12 / 10 / 2020 at New Delhi by


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Joseph & Mary Public School, Nathu Pura, Road, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".